

## DECLARATION OF PERFORMANCE

No.: DoP-17-9007-01

- |   |  |  |         |
|---|--|--|---------|
| 1 | Unique identification code of the product-type | NYM 300/500V multicore with circular conductors  |         |
| 2 | Range  | according to classification report   |         |
| 3 | Intended use/es                                | Cable for general applications in construction works<br>subject to reaction to fire requirements<br>TF KABLE FABRIKA KABLOVA ZAJECAR DOO |         |
| 4 | Manufacturer                                   | FK ZAJECAR<br>Negotinski put b.b.<br>19000 Zaječar - Serbia  |         |
| 5 | System/s of AVCP                               | 3  |         |
| 6 | Harmonised standard                            | EN 50575:2014+A1:2016  |         |
| 7 | Notified body/ies                              | Instytut Techniki Budowlanej   | NB 1488 |
| 8 | Declared performance/s                         | Reaction to fire:  | Eca     |

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by: Olivera Milić, Slaviša Marković

Zaječar, 31.07.2017  
(place, date of issue)

(first and last name)  
OLIVERA MILIĆ  
SLAVIŠA MARKOVIĆ  
SEPTENTRIONALNE KONTROLE  
(signature)  
Olivera Milić